

# A Modified PSO Approach for Reactive Power Compensation in Power System Distribution Networks

<sup>1</sup>Kumar Saurav, <sup>2</sup>Prof. Anjana Tripathi

<sup>1</sup>M.Tech Scholar, Dept. of Electrical and Electronics Engineering, SCOPE College of Engineering, Bhopal, India,

<sup>2</sup>Assistant Professor, Dept. of Electrical and Electronics Engineering, SCOPE College of Engineering, Bhopal, India

**Abstract** - The power compensation is the one of the problem in distribution network. The power compensation is done by maintain the reactive power in distribution network. The power is maintain the state of the Unified power quality conditioner (UPQC). The UPAC controlled by the STATCOM or DSTATCOM. Different approaches use to maintain the power at needed level in the power distribution network the process done by MOPSO optimization method the MOPSO is the best for this process because we consider the lot of objective function to optimize the place of the UPQC. In our proposed work we find the power level in distribution network using optimization algorithm. The optimization algorithm is used to optimization the power and find which place is suitable for place the STATCOM or DSTATCOM. This is used to maintain the reactive power in distribution network.

**Keywords-** UPQC, PSO, MOPSO, STATCOM, DSTATCOM Power, Reactive, Optimization, compensation.

## I. INTRODUCTION

Power systems are large and complex electrical networks. In any power system, generations are located at few selected points and loads are distributed throughout the network. In between generations and loads, there exist transmission and distribution systems. In the power system, the system load keeps changing from time to time as shown.

Force flow investigation is worried about depicting the working condition of a whole force framework, by which we mean a system of generators, transmission lines, and loads that could speak to a zone as little as a region or as extensive as a few states. Given certain known amounts—ordinarily, the measure of intensity produced and expended at various areas—power flow investigation permits one to decide different amounts.

The most significant of these amounts are the voltages at areas all through the transmission framework, which, for substituting current (A.C.), comprise of both an extent and a period component or stage edge. When the voltages are known, the flows flowing through each transmission connection can be effortlessly determined. Therefore the name power flow or load flow, as it is regularly brought in the business: given the measure of intensity conveyed and where it originates from, power flow investigation discloses to us how it flows to its goal.




Figure 1: Active and Reactive Power



```

2  2  1.043  0   40  50.0  21.7  12.7  -40  50;
3  3  1.0    0   0   0    2.4   1.2   0    0;
4  3  1.06   0   0   0    7.6   1.6   0    0;
5  2  1.01   0   0  37.0  94.2  19.0  -40  40;
6  3  1.0    0   0   0    0.0   0.0   0    0;
7  3  1.0    0   0   0   22.8  10.9   0    0;
8  2  1.01   0   0  37.3  30.0  30.0  -10  40;
9  3  1.0    0   0   0    0.0   0.0   0    0;
10 3  1.0    0   0  19.0   5.8   2.0   0    0;
11 2  1.082   0   0  16.2   0.0   0.0   -6   24;
12 3  1.0    0   0   0   11.2   7.5   0    0;
13 2  1.071   0   0  10.6   0.0   0.0   -6   24;
14 3  1.0    0   0   0    6.2   1.6   0    0;

```

The active power controller aims to maintain the active power output constant at a given reference value within the permissible frequency range. The reactive power controller aims to maintain the reactive power output constant at the given reference value within the permissible voltage range.

#### Constraints and Variable:

```

nbus=14;
fb = linedata(:,1);
tb = linedata(:,2);
r = linedata(:,3);
x = linedata(:,4);
b = linedata(:,5);
a = linedata(:,6);
z = r + i*x;
y = 1./z;
b = i*b;
nb = max(max(fb),max(tb));
nl = length(fb);
Y = zeros(nb,nb);

```

```

busd=BData;
BMva = 100;
bus = busd(:,1);
type = busd(:,2);
V = busd(:,3);
del = busd(:,4);
Pg = busd(:,5)/BMva;
Qg = busd(:,6)/BMva;
Pl = busd(:,7)/BMva;
Ql = busd(:,8)/BMva;
Qmin = busd(:,9)/BMva;
Qmax = busd(:,10)/BMva;
P = Pg - Pl;
Q = Qg - Ql;
Psp = P;
Qsp = Q;
G = real(Y);
B = imag(Y);
pv = find(type == 2 | type == 1);
pq = find(type == 3);
npv = length(pv);
npq = length(pq);
Tol = 1;
Iter = 1;

```

#### Objective Functions:

- Minimization of active power loss:

$$\min f1 = \sum^{Nb-1} (Ik)^2 Rk$$


- Minimization of reactive power loss:

$$\min f2 = \sum^{Nb-1} (Ik)^2 Xk$$

$Nb$  represents number of buses;  $Ik$  represents current in  $k^{th}$  branch;  $Rk + jXk$  is the impedance of  $k^{th}$  branch

- Overall Objective Functions:  $f = w1 * f1 + w2 * f2$
- $w1$  and  $w2$  are weight constants assigned to each objective, such that  $w1 + w2 = 1$
- Here equal importance is given to both the objectives, so  $w1 = 0.5$  and  $w2 = 0.5$

### III. SIMULATION & RESULT



BUS	TYPE	SOURCE VOLTAGE	THETA	ACTIVE POWER(Gen)	RE-ACTIVE POWER(Gen)	ACTIVE POWER(Load)	RE-ACTIVE POWER(Load)	RE-ACTIVE POWER(min)	RE-ACTIVE POWER(max)
1	1	1.0000	0	0	0	0	0	0	0
2	2	1.0430	0	40	50	21.7000	12.7000	-40	50
3	3	1	0	0	0	2.4000	1.2000	0	0
4	4	1.0000	0	0	0	7.6000	1.6000	0	0
5	5	1.0100	0	0	37	94.2000	19	-40	40
6	6	1	0	0	0	0	0	0	0
7	7	1	0	0	0	22.8000	10.9000	0	0
8	8	1.0100	0	0	37.3000	30	30	-10	40
9	9	1	0	0	0	0	0	0	0
10	10	1	0	0	19	5.8000	2	0	0
11	11	1.0020	0	0	16.2000	0	0	-6	24
12	12	1	0	0	0	11.2000	7.5000	0	0
13	13	1.0710	0	0	10.8000	0	0	-6	24
14	14	1	0	0	0	6.2000	1.6000	0	0

Figure 4: IEEE 14 Bus system data

In figure 4, all the informational collection or qualities are appearing of 14 transport frameworks. In which source voltage, dynamic force, responsive force regarding age, burden, min and max are appearing.

1 sub1

□ □ □

POWER FLOW

	BUS	VOLTAGE(pu)	ANGLE	INJECTION P(MW)	INJECTION Q(MVAr)	
1	1	1.0000	0	200.6200	-17.4	▲
2	2	1.0430	-5.3474	18.3000	30	
3	3	1.0217	-2.5440	-2.4000	-1	
4	4	1.0129	-9.2869	-7.6000	-1	
5	5	1.0100	-14.1542	-84.2000	19	
6	6	1.0121	-11.0880	3.4196e+12	10	
7	7	1.0035	-12.0734	-22.8000	-10	
8	8	1.0100	-11.8039	-30.0000	0	
9	9	1.0507	-14.1383	3.6230e+13	17	
10	10	1.0430	-15.7341	-5.8000	17	
11	11	1.0020	-14.1383	0	16	
12	12	1.0678	-14.9416	-11.2000	-2	
13	13	1.0710	-14.9416	0	10	
14	14	1.0429	-15.8244	-8.2000	-1	
	<				>	

	FROM	TO	P(MW)	Q(MVAr)	FROM	TO
1	1	2	173.1430	-18.1078	2	1
2	1	3	87.7949	6.2470	3	2
3	2	4	43.8185	5.1943	4	3
4	3	5	82.2892	-3.7720	4	5
5	2	6	82.2829	4.0325	5	6
6	2	6	69.3529	1.4024	6	7
7	4	6	72.2720	-17.5214	6	7
8	5	7	-14.8525	11.7958	7	9
9	6	7	38.1954	-1.2007	7	10
10	6	8	29.4887	-3.2137	8	11
11	6	9	27.7995	-10.4048	9	12
12	6	10	15.8822	-5.3058	10	13
13	9	11	-2.8817e+15	-15.7993	11	14
14	9	10	27.7995	7.0412	10	14
	<				>	

MPSO

FINAL RESULT

Total loss before optimization : 43.208

Activate Windows  
Go to Settings to activate Windows.

Figure 5: Power loss in flow before optimization

In figure 5, indicating absolute misfortune in influence stream improvement. Here utilizing proposed approach for example molecule swarm improvement to advance receptive force.




Figure 6: Proposed approach Iteration process

In figure 6, indicating emphasis approach utilizing PSO calculation, in which wellness esteem determined and Gbest versus time chart produced.


Figure 7: Average reactive power after optimization. The table shows power flow data after optimization. The total loss before optimization was 43.208, and the total loss after MPSO optimization is 10.8287.

BUS	VOLTAGE(pu)	ANGLE	INJECTION P(MW)	INJECTION Q(MVAr)	FROM	TO	P(MW)	Q(MVAr)	FROM	TO	
1	1.0000	0	200.6200	-17.4	1	2	173.1430	-18.1078	2	1	
2	1.0430	-5.3474	18.3000	30	2	1	87.7949	6.2470	3	2	
3	1.0217	-2.5440	-2.4000	-1	3	2	43.8185	5.1943	4	3	
4	1.0129	-9.2869	-7.6000	-1	4	3	82.2892	-3.7720	4	5	
5	1.0100	-14.1542	-84.2000	19	5	2	82.2829	4.0325	5	6	
6	1.0121	-11.0880	3.4196e+12	10	6	2	69.3529	1.4024	6	7	
7	1.0035	-12.0734	-22.8000	-10	7	4	72.2720	-17.5214	6	7	
8	1.0100	-11.8039	-30.0000	0	8	5	7	-14.8525	11.7958	7	9
9	1.0507	-14.1383	3.6230e+13	17	9	6	7	38.1954	-1.2007	7	10
10	1.0430	-15.7341	-5.8000	17	10	6	8	29.4887	-3.2137	8	11
11	1.0020	-14.1383	0	16	11	6	9	27.7995	-10.4048	9	12
12	1.0678	-14.9416	-11.2000	-2	12	6	10	15.8822	-5.3058	10	13
13	1.0710	-14.9416	0	10	13	9	11	-2.8817e+15	-15.7993	11	14
14	1.0429	-15.8244	-8.2000	-1	14	9	10	27.7995	7.0412	10	14

Total loss Before optimization : 43.208  
Total loss MPSO optimization : 10.8287

Figure 7: Average reactive power after optimization

In figure 7, absolute misfortune improvement is appearing by utilizing PSO approach. Before streamlining power, misfortune is 43.208 and after advancement it gets 10.8287.



Selected BUS	Injection power	UPQC-Type
1	1	10 UPQC-P
2	2	10 UPQC-P
3	3	17.5000 UPQC-P
4	4	17.5000 UPQC-P
5	5	17.5000 UPQC-P
6	6	20 UPQC-S
7	7	20 UPQC-S
8	8	17.5000 UPQC-P
9	9	20 UPQC-S
10	10	10 UPQC-P
11	11	17.5000 UPQC-P

Selected BUS	Injection power	UPQC-Type
1	2	10 UPQC-P
2	2	10 UPQC-P
3	3	17.5000 UPQC-P
4	4	20 UPQC-P
5	5	20 UPQC-P
6	6	17.5000 UPQC-S
7	7	10 UPQC-S
8	8	17.5000 UPQC-P
9	9	17.5000 UPQC-S
10	10	20 UPQC-P

Figure 8: Final result values

In figure 8, indicating conclusive outcome esteems in information transports. Bound together force quality conditioner (UPQC), which is otherwise called the general dynamic channel. UPQC has shunt and arrangement remuneration capacities for sounds, receptive force, voltage aggravations, and force stream control.




Figure 9: Power loss, PSO vs Proposed

Figure 9 indicating power misfortune versus UPQC rate in the event of particle swarm optimization (PSO) and proposed Modified PSO. Simulation results show that the power loss is optimized and minimized by using the proposed approach.

Table 1: Result Comparison

Sr No.	Parameters	Existing work result	Proposed Work result
1	Method	PSO	MPSO
2	No of Bus	14-Bar	14-Bar
3	Iteration	200k or (200000)	100000
4	Loss before optimization	13.393	43.208
5	Loss after optimization	12.36	10.8287

#### IV. CONCLUSIONS

Reactive power the board assumes a crucial job in improving force nature of the framework. The significant worry in responsive force the executive is area and amount of putting capacitor at ideal area in the spiral/work/interconnected dispersions arrange is multi-goals work with specific limitations. In proposed work we utilize the IEEE 14 transport framework for investigation the Interest reaction utilizing the MATLAB condition. In this paper proposed alter PSO based force stream is discover the interest reaction in the IEEE transport framework. Lastly determined the DG place transports and it is capacity to upgrade the force framework. Result shows that proposed work gives great outcome for pick the transports for adjusted the force stream in IEEE framework through receptive force advancement and pay.

#### REFERENCES

1. H. Modha and V. Patel, "Minimization of Active Power Loss for Optimum Reactive Power Dispatch using PSO," *2021 Emerging Trends in Industry 4.0 (ETI 4.0)*, Raigarh, India, 2021, pp. 1-5, doi: 10.1109/ETI4.051663.2021.9619313.



2. K. Murugesan, M. Senthil Kumaran, J. Anitha Roseline, S. Vijayenthiran, M. Kubera Murthi and A. C. Maheswari, "DSTATCOM Using Matrix Converter for Reactive Power Compensation," *2019 Fifth International Conference on Electrical Energy Systems (ICEES)*, Chennai, India, 2019, pp. 1-6.
3. A. Samir, M. Taha, M. M. Sayed and A. Ibrahim, "Efficient PV-grid system integration with PV-voltage-source converter reactive power support," in *The Journal of Engineering*, vol. 2018, no. 2, pp. 130-137, 2 2018.
4. S. Stanković and L. Söder, "Analytical Estimation of Reactive Power Capability of a Radial Distribution System," in *IEEE Transactions on Power Systems*, vol. 33, no. 6, pp. 6131-6141, Nov. 2018.
5. M. Moghbel, M. A. S. Masoum, A. Fereidouni and S. Deilami, "Optimal Sizing, Siting and Operation of Custom Power Devices With STATCOM and APLC Functions for Real-Time Reactive Power and Network Voltage Quality Control of Smart Grid," in *IEEE Transactions on Smart Grid*, vol. 9, no. 6, pp. 5564-5575, Nov. 2018.
6. S. Gao, H. Wang, C. Wang, S. Gu, H. Xu and H. Ma, "Reactive power optimization of low voltage distribution network based on improved particle swarm optimization," *2017 20th International Conference on Electrical Machines and Systems (ICEMS)*, Sydney, NSW, 2017, pp. 1-5.
7. V. N. Tulskey, M. A. Tolba, A. A. Radwan, O. M. Foly and A. A. Z. Diab, "Measurement and analysis of an electric power distribution system with optimal reactive power compensation for improving the power quality. Case study: Middle Egypt region," *2017 IEEE Conference of Russian Young Researchers in Electrical and Electronic Engineering (EIConRus)*, St. Petersburg, 2017, pp. 1613-1618.
8. N. S. Lakra, P. Prakash and R. C. Jha, "Power quality improvement of distribution system by reactive power compensation," *2017 International Conference on Power and Embedded Drive Control (ICPEDC)*, Chennai, 2017, pp. 415-420.
9. P. Dong, L. Xu, Y. Lin and M. Liu, "Multi-Objective Coordinated Control of Reactive Compensation Devices Among Multiple Substations," in *IEEE Transactions on Power Systems*, vol. 33, no. 3, pp. 2395-2403, May 2017.
10. M. Moghbel, M. A. S. Masoum, A. Fereidouni and S. Deilami, "Optimal Sizing, Siting and Operation of Custom Power Devices With STATCOM and APLC Functions for Real-Time Reactive Power and Network Voltage Quality Control of Smart Grid," in *IEEE Transactions on Smart Grid*, vol. 9, no. 6, pp. 5564-5575, Nov. 2018.
11. A. K. Bohre, G. Agnihotri and M. Dubey, "Optimal sizing and sitting of DG with load models using soft computing techniques in practical distribution system," in *IET Generation, Transmission & Distribution*, vol. 10, no. 11, pp. 2606-2621, 4 8 2016.
12. X. Zhang, X. Wang and X. Qi, "Reactive power optimization for distribution system with distributed generations based on AHSPSO algorithm," *2016 China International Conference on Electricity Distribution (CICED)*, Xi'an, 2016, pp. 1-4.